

PRACTICAL INFORMATION 2

The planning and realization of hazardous substances storage requires the reconciliation of countless individual aspects. For example type and quantity of stored hazardous substances, local conditions and available space, the legal regulations and official requirements, and not at least the available budget has to be brought to a common denominator. Our checklist is intended to help you with this.

Checklist for storage of water-endangering and/or flammable liquids

Clear classification of the substances be stored

Water-endangering liquids / flammable liquids

- Resistance of the trays material (e.g. storage of aggressive media)
- Type of containers (small containers, 200 liter drums, IBC...)
- Quantity of containers
- Sump capacity
- Walk-in or shelving storage
- Available or planned handling equipment
- Water protection area
- Official requirements



Water-endangering liquids



Flammable liquids

- Site
- F90-system, F90-wall or at least 10 meters distance
- Ventilation
- Ex-proof electrical equipment
- Official and/or fire fighting requirements
- Fire protection requirements (fighting system, fire detection, fire fighting water retention...)



Please let us know about used container sizes, pallet sizes, required load capacity or compartment height. This might be helpful to submit an offer.

Please note that we are only able to render assistance at this. Each case must be considered separately. We are pleased to assist you gladly.